



GALVANIZED STEEL FRAMING

REPLACEABLE FILTER BAG
(22" MIN. TOTAL DEPTH)

NONWOVEN FABRIC
(12" MIN. DEPTH)

FRAMED INLET PROTECTION SHALL
BE FLEXSTORM INLET FILTER OR
APPROVED EQUAL.

CURB BACK EXTENSION REQUIRED
FOR CURB INLETS.

INLET PROTECTION SHALL BE
MAINTAINED OR REPLACED AT
DIRECTION OF THE ENGINEER.

WHEN REMOVING OR MAINTAINING
INLET PROTECTION, CARE SHALL
BE TAKEN SO THAT THE
SEDIMENT TRAPPED DOES NOT
FALL INTO THE INLET. ANY
MATERIAL FALLING INTO THE INLET
SHALL BE REMOVED IMMEDIATELY.

INSTALLATION

1. REMOVE GRATE.
2. DROP INLET FILTER ONTO
LOAD BEARING LIP OF
CASTING OR CONCRETE
STRUCTURE.
3. REPLACE GRATE.



CITY OF MIDDLETON
STANDARD DETAIL

INLET PROTECTION
FRAMED

REVISED
DRAWN BY:

07-31-2025
LTM

100-04