



### NOTES

MANHOLE FRAME & LID TO BE  
NEENAH FOUNDRY CO. No R-1670-A,  
TYPE B NON-ROCKING LID, WITH 2  
CONCEALED PICK HOLES.

STEPS TO BE M.A. INDUSTRIES, INC.  
No. PS1-PF, OR EQUAL.

ALL LIFT HOLES & PIPE CONNECTIONS  
TO BE SEALED WITH HYDRAULIC CEMENT.

MANHOLE DIAMETER TO BE SIZED PER  
MANUFACTURER RECOMMENDATION TO  
PROVIDE 12" MIN. CONCRETE BETWEEN  
PIPE OPENINGS.

ADJUSTMENT RINGS SHALL BE CONFIGURED  
TO MINIMIZE NUMBER OF RINGS REQUIRED.

|   |  |
|---|--|
| <small>C:\City Logo\City Logo.jpg</small> | <b>CITY OF MIDDLETON<br/>STANDARD DETAIL</b> |
| <b>STORM SEWER<br/>MANHOLE</b>            |  |
| <small>REVISED<br/>DRAWN BY:</small>      | <small>10-25-2023<br/>SAU</small>            |
| <b>300-06</b>                             |  |