



ADJUSTMENT RINGS  
4" MIN. - 12" MAX

PRECAST REINFORCED  
CONCRETE CONCENTRIC  
CONE. IF IN CURB LINE,  
USE INSTEAD PRECAST  
FLAT SLAB TOP WITH  
RECTANGULAR OPENING.

6"x6" CONCRETE FILLET  
ENTIRE PERIMETER OF BASE

**NOTES**

MANHOLE FRAME & LID TO BE  
NEENAH FOUNDRY CO. No R-1726-A,  
TYPE B NON-ROCKING LID, WITH 2  
CONCEALED PICK HOLES, OR FRAME & GRATE  
NEENAH FOUNDRY CO. No R-2500-D.

STEPS TO BE M.A. INDUSTRIES, INC.  
No. PS1-PF, OR EQUAL.

ALL LIFT HOLES & PIPE CONNECTIONS  
TO BE SEALED WITH HYDRAULIC CEMENT.

MANHOLE DIAMETER TO BE SIZED PER  
MANUFACTURER RECOMMENDATION TO  
PROVIDE 12" MIN. CONCRETE BETWEEN  
PIPE OPENINGS.

ADJUSTMENT RINGS SHALL BE CONFIGURED  
TO MINIMIZE NUMBER OF RINGS REQUIRED.

BEDDING  
MATERIAL

	<p><b>CITY OF MIDDLETON STANDARD DETAIL</b></p>
<p><b>CATCH BASIN</b></p>	
<p>REVISED DRAWN BY:</p>	<p>06-05-2014 SKS</p>
<p>300-7</p>	