



NOTES

1. ALL FITTINGS SHALL CONFORM TO AWWA STANDARDS.
2. ALL COPPER COUPLINGS SHALL BE OF COMPRESSION JOINT TYPE.
3. ALL CORPORATION STOP TAPS SHALL BE MADE UNDER PRESSURE.
4. ALL COPPER TUBE BENDS SHALL BE SMOOTH RADIUS, 6" MIN.
5. CORPORATION STOP TAPS SHALL NOT BE WITHIN 18" OF OTHER TAPS OR WITHIN 24" OF WATER MAIN JOINTS.
6. WATER SERVICE LATERAL SHALL BE TESTED ALONG WITH WATER MAIN, EXCEPT ON WATER MAIN REPLACEMENT PROJECTS.
7. END OF WATER SERVICE SHALL BE CRIMPED WATER TIGHT UNTIL CONNECTION TO HOUSE IS MADE.

	<p>CITY OF MIDDLETON STANDARD DETAIL</p>
<p>WATER SERVICE</p>	
<p>REVISED DRAWN BY:</p>	<p>08-05-2014 AMK</p>
<p>400-3</p>	