



THRUST BLOCK DIMENSION

DIA.	A	B	C	D
8"	1'-6"	1'-10"	1	2
12"	2'-5"	1'-10"	SEE NOTE NO. 1	SEE NOTE NO. 2
16"	3'-4"	2'-4"	SEE NOTE NO. 1	SEE NOTE NO. 2
20"	4'-3"	2'-10"	SEE NOTE NO. 1	SEE NOTE NO. 2
24"	5'-2"	3'-4"	SEE NOTE NO. 1	SEE NOTE NO. 2
30"	6'-9"	4'-0"	SEE NOTE NO. 1	SEE NOTE NO. 2

NOTES

1. DIMENSION C SHOULD BE LARGE ENOUGH TO MAKE ANGLE θ EQUAL TO OR LARGER THAN 45°.
2. DIMENSION D EQUALS APPROXIMATE ID OF PIPE LESS 2".
3. PROVIDE MEGALUGS® ON ALL FITTINGS AND ON ALL JOINTS WITHIN 20' OF FITTING.

	CITY OF MIDDLETON STANDARD DETAIL
THRUST BLOCK FOR DEAD ENDS	
REVISED DRAWN BY:	08-08-2014 AMK
400-6	